


Axelrod
922



Randall W. Hardy, Superintendent
Charles Royer, Mayor

May 26, 1989

Wilder Construction
2006 N. State. St.
Bellingham, WA 98225

Gentlemen:

Underground Tanks
Specification No. 2928

In reviewing your May 8, 1989 letter, we note the NW Enviro Service quote of \$2,770.00 provided for pumping and disposal of tanks from both South Service Center and Georgetown Steamplant but did not include anything for pumping and disposal of oil from pipes which is the subject of your claim. Be aware that the capacity of the 195' of 2" and 8" pipe to have been removed under the contract is computed to be 826 gallons. We acknowledge that a small amount of additional oil entered the piping system at Georgetown Steamplant but certainly not twenty five per cent of the total oil removed from both sites as your claim would indicate. To settle this matter we have prepared a C.O. Item 8A in the amount of \$300.00 for this work.

Regarding your claim for \$2,200.72 for off site cleaning and disposal of additional piping removed from Georgetown Steamplant we know the work performed on 3/23, 24 and 27 included a 12,000 gallon tank, contract piping and additional piping. The Engineer has determined that the additional piping constituted 37 1/2% of this total work and therefore we have prepared a C.O. Item 8B of \$825.00 for it's payment.

Yours truly,

Original Signed by:
CHARLES J. WEEMS, P.E.
DIRECTOR, CONSTRUCTION ENGINEERING

Charles J. Weems, P.E.
Director, Construction Engineering

WES:elc

Enclosure: Change Order No. 8

bcc: 822/Schwartz
Summers/Wang
Chu
Axelrod
File

SCL 04277

CTY0049283

SEA289762